

OT Vulnerability Research

Why open source vulnerability databases are not good for ICS



kaspersky





gemalto^x

Schneider Electric





















Honeywell

YOKOGAWA








EMERSON

flexera





The talk is about





Data Quantity Problems



Data Quality Problems



Information sources

Vendor advisories

CISA (ICS/US-CERT)

CVE Project (MITRE) / NVD



Vendor Advisories
















Yokogawa Security Advisory Report

Yokogawa Security Advisory Report

YSAR-24-0002

Published on Last updated on June 17, 2024 July 4, 2024

YSAR-24-0002: DLL Hijacking Vulnerability in CENTUM CAMS Log server

Overview

DLL Hijacking vulnerability has been found in CENTUM CAMS Log server. Yokogawa has identified the range of affected products in this report.

Please review the report and confirm which products are affected to implement security measures for the overall systems. Please consider applying the countermeasures as needed.

Affected Products:

This vulnerability affects the following products.

CENTUM series


OLIVI OW SCHOO		
CENTUM CS 3000	R3.08.10 - R3.09.50	LHS1100/LHM1101 Standard Operation and Monitoring Function (Affected even if CAMS is not enabled)
CENTUM VP	R4.01.00 - R4.03.00 R5.01.00 - R5.04.20	LHS1100/LHM1101 Standard Operation and Monitoring Function (Affected even if CAMS is not enabled)
	R6.01.00 - R6.11.10	VP6H1100 Standard Operation and Monitoring Function (Affected even if CAMS is not enabled)

Vulnerability:

If an attacker is somehow able to intrude into a computer that installed affected product or access to a shared folder, by replacing the DLL file with a tampered one, it is possible to execute arbitrary programs with the authority of the SYSTEM account.

CWE-284: Improper Access Control CVE: CVE-2024-5650 CVSS v3 Base score: 8.5 CVSS:3.0/AV:N/AC:H/PR:L/UI:N/S:C/C:H/I:H/A:H





```
"vulnerabilities": [
    "cve": "CVE-2024-43647",
    "cwe": {
       <u>"id": "CWE-4</u>00",
       "name": "Uncontrolled Resource Consumption"
     },
    "product_status": {
       "known_affected": [
            https://cert-portal.siemens.com/productcert/csaf/ssa-969738.json
```

Problems




Vulnerabilities of only one vendor




Human-readable data (for most vendors)







23% ICS vulns are missing from CISA





An authorization bypass vulnerability exists in Schneider Electric's Modicon M340, Modicon Premium, Modicon Quantum PLC, BMXNOR0200.





Researcher discovers vulnerability

Researcher reports to vendor

Vendor publishes advisory

Vendor reports to CISA

CISA publishes advisory



Researcher discovers vulnerability

Researcher reports to vendor

Vendor publishes advisory


Vendor reports to CISA

CISA publishes advisory



The following versions of Advantech WebAccess HMI Designer, a Human Machine Interface (HMI) runtime development software, are affected:

 Advantech WebAccess HMI Designer Version 2.1.9.23 and prior





```
"vulnerabilities": [
    "cve": "CVE-2019-10961",
    "cwe": {
       "id": "CWE-787",
       "name": "Out-of-bounds Write"
     },
    "product_status": {
       "known_affected": [
          "CSAFPID-0001"
            https://github.com/cisagov/CSAF/blob/develop/csaf_files/OT/white/2019/icsa-19-213-01.json
```

CISA: Missing updates

August 2024 Update: A remediation is available on Modicon M580 CPU Safety (page 2).

Affected Products and Versions

Product	Version
EcoStruxure™ Control Expert All ve	
EcoStruxure™ Process Expert All version	
Modicon M340 CPU (part numbers BMXP34*)	All versions
Modicon M580 CPU (part numbers BMEP* and BMEH*)	Versions prior to SV4.20
Modicon M580 CPU Safety (part numbers BMEP58*S and BMEH58*S)	Versions prior to SV4.21
Modicon Momentum Unity M1E Processor (171CBU*)	All versions
Modicon MC80 (BMKC80)	All versions

3.1 AFFECTED PRODUCTS

The following components of Schneider Electric EcoStruxure and Modicon are affected:

- EcoStruxure Control Expert: All versions
- EcoStruxure Process Expert: All versions
- Modicon M340 CPU (part numbers BMXP34*): All versions
- Modicon M580 CPU (part numbers BMEP* and BMEH*): All versions
- Modicon M580 CPU Safety (part numbers BMEP58*S and BMEH58*S): All versions
- Modicon Momentum Unity M1E Processor (171CBU*): All versions
- Modicon MC80 (BMKC80): All versions



- https://download.schneider-electric.com/files?p_Doc_Ref=SEVD-2023-010-06&p_enDocType=Security+and+Safety+Notice&p_File_Name=SEVD-2023-010-06_Modicon_Controllers_Security_Notification.pdf
- https://www.cisa.gov/news-events/ics-advisories/icsa-23-227-01

As of January 10, 2023, CISA will no longer be updating ICS security advisories for Siemens product vulnerabilities beyond the initial advisory. For the most up-to-date information on vulnerabilities in this advisory, please see <u>Siemens' ProductCERT Security Advisories (CERT Services | Services | Siemens Global).</u>



Problems



Amount of data




Human-readable data (for old vulnerabilities)



Missing updates
















CVE Project: Missing Information

SD1701 | RSLogix™ 5 and RSLogix 500° Remote Code Execution Via VBA Embedded Script

CVE IDs

CVE-2024-7847

Severity: High

Advisory ID: SD1701

ry: High

Published Date: September 16, 2024 Last Updated: September 16, 2024

Revision Number: 1.0

Known Exploited Vulnerability (KEV): No

Corrected: No Workaround: No


Summary

SD1701 | RSLogix™ 5 and RSLogix 500® Remote Code Execution Via VBA Embedded Script

Published Date: September 19, 2024

Last updated: September 19, 2024

Revision Number: 1.0





- https://www.rockwellautomation.com/en-ch/trust-center/securityadvisories/advisory.SD1701.html
- https://www.cve.org/CVERecord?id=CVE-2024-7847



Publish advisory


Publish CVE



Request CVE ID Publish advisory


Publish CVE

























Problems



Need to filter ICS vulnerabilities



Delay




Missing vulnerabilities



Missing updates









NVD: Information Enrichment

Current Description

A CWE-294: Authentication Bypass by Capture-replay vulnerability exists that could cause execution of unauthorized Modbus functions on the controller when hijacking an authenticated Modbus session. Affected Products: EcoStruxure Control Expert (All Versions), EcoStruxure Process Expert (All Versions), Modicon M340 CPU - part numbers BMXP34* (All Versions), Modicon M580 CPU - part numbers BMEP3* and BMEH4* (All Versions), Modicon M580 CPU - Safety - part numbers BMEP3* and BMEH58*S (All Versions)

+View Analysis Description



References to Advisories, Solutions, and Tools


By selecting these links, you will be leaving NIST webspace. We have provided these links to other web sites because they may have information that would be of interest to you. No inferences should be drawn on account of other sites being referenced, or not, from this page. There may be other web sites that are more appropriate for your purpose. NIST does not necessarily endorse the views expressed, or concur with the facts presented on these sites. Further, NIST does not endorse any commercial products that may be mentioned on these sites. Flees address comments about this page to mydifinist, govern


Hyperlink	Resource
https://download.schneider-electric.com/files?p_Doc_Ref=SEVD-2023-010-	Patch
06&p_enDocType=Security+and+Safety+Notice&p_File_Name=SEVD-2023-010-	Vendor Advisory
06_Modicon_Controllers_Security_Notification.pdf	

Weakness Enumeration

CWE-ID	CWE Name	Source
CWE-294	Authentication Bypass by Capture-replay	Schneider Electric SE







Problems



Delay



Need to filter ICS vulnerabilities



Missing vulnerabilities



Missing updates



Problems



Delay



Need to filter ICS vulnerabilities



Missing vulnerabilities




Missing updates and enrichment errors



Errors 35







A CWE-248 Uncaught Exception vulnerability exists which could cause a denial of service when sending invalid debug parameters to the controller over Modbus.







CVSSv3 Base Score: 7.5 (High)

AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H






Acknowledgements

Schneider Electric recognizes the following researcher(s) for identifying and helping to coordinate a response to these vulnerabilities:

CVE
CVE-2018-7843, CVE-2018-7844, CVE-2018-7845, CVE-2018-7850, CVE-2018-7852, CVE-2018-7853, CVE-2018-7854, CVE-2018-7855, CVE-2018-7856, CVE-2019-6806, CVE-2019-6807, CVE-2019-6808, CVE-2019-6809, CVE-2019-6828, CVE-2019-6829, CVE-2019-6830



This can be completed by first obtaining a **PLC reservation**, and then sending a data payload ...







Privileges Required: None -> High






Privileges Required: None -> High Availability: High -> None

CVSSv3 Base Score: 0.0 (None)










78% ICS vulns with errors



Recommendations



Monitor all information sources



Perform a vulnerability analysis



Staff trainings



Thank you!

https://ics-cert.kaspersky.com



Artem Zinenko

Head of ICS CERT Vulnerability Research and Assessment

Artem.Zinenko@kaspersky.com

kaspersky

